Kenn



December 18, 2012

JAN 03 2013 3AP20

VIA CERTIFIED MAIL # 7012 1640 0002 4116 0924

Director; Air, Pesticides, and Toxics Division U.S. Environmental Protection Agency 1650 Arch Street Philadelphia, PA 19103

Re:

NSPS Subpart JJJJ Notification of Construction

Appalachia Midstream Services

Battle Run Compressor Station - Plant ID. No. 069-00107

To Whom It May Concern:

Per 40 C.F.R. § 60.7(a)(1), Appalachia Midstream Services is submitting this notification of construction for one affected facility at Battle Run Compressor Station as defined by NSPS Subpart JJJJ: GEN-94. Enclosed is information required by NSPS Subpart A. If you have any questions, please contact me at (405) 935-8413 or by email at AirGroup@accessmidstream.com

Sincerely,

Kyle Kauk Specialist - Air

Access Midstream Partners

CC:

WV Department of Environmental Protection

Division of Air Quality

601 57th Street

Charleston, WV 25304

VIA CERTIFIED MAIL # 7012 1640 0002 4116 0948

WV Department of Air Quality Northern Panhandle Regional Office 131A Peninsula Street Wheeling, WV 26003

VIA CERTIFIED MAIL # 7012 1640 0002 4116 0955
Access Midstream

P.O. Box 18355, Oklahoma City, OK 73154-0355 877-413-1023

Appalachia Midstream Services 40 CFR 60 Subpart JJJJ **NSPS Subpart A Initial Notification Battle Run Compressor Station GEN-94**

Owner Information:

Name:

Appalachia Midstream Services

Address:

6100 N. Western Ave., PO Box 18162

Oklahoma City, OK 73154-0162

Facility Information:

Name:

Battle Run Compressor Station

Location:

County: Ohio

State: WV

40.073482, -80.572531

Engine Information:

Make/Model:

Baldor IGLC420-2N NG Gener

Engine Family:

4SRB

Serial Number:

EEY0F100135

Manufacture Date:

1/26/2012

Maximum Rated HP:

605

Engine Displacement (in³): 1338

Emission Control Information: NSCR

Fuel Used: Natural gas

Construction Start Date: 10/30/2012

Additional Submittal Information: Manufacturer will not certify the engine.